

## The Corporation of the Township of Gillies Addendum to RFP document for:

## Request for Proposals # 2025-01 Hymers Fair Drive Road Work

The purpose of this Addendum is to clarify road work questions submitted during the site visit.

- 1. Ditching required is 1 km
- 2. Width of road is 22 ft
- 3. Length of road is 5.5 km
- 4. Lift of gravel is 4"
- 5. Type of Gravel Driveway Mix
- 6. The gravel will be supplied and applied by the bidder.
- 7. The Roads Department will prepare the road prior to work beginning.
- 8. The Roads Department will post on markers exactly where the ditching work will begin and end.
- 9. Frost boil remediation is to be included in the proposal as an additional cost per remediation and not part of the base cost. The Roads Department will inform the successful bidder of any extra remediation work that is required.
- 10. Each person submitting a proposal will be required to give a start date for work to begin.

## 4. Effective Date

This Addendum shall become effective on May 15, 2025 and shall form part of the RFP 2025-01 Hymers Fair Drive Road Work.

## 5. Signatures

By signing below, the parties acknowledge and agree to the modifications set forth in this Addendum. Include this signed addendum in your submission.

Name and Title:		
-		

Organization:	

Date:	

Signature: \_\_\_\_\_